

BUILDING INSPECTION NOTICE

B-Complete; E-Complete; M-Complete; P-Complete

Permit #: 14-002176-RS

LI: Kevin Kilmer

Supervisor Tel: 408 535-6863

Preferred:

Confirmation #: 01399737

Received: 08/29/2018

By: Phone

Scheduled: 09/13/18

Tract: 8474

Lot: 9

of Units: 0 Map: 875 G 1

Address: 2012 BIARRITZ PL SAN JOSE

Contact: TUAN

Phone: (408) 786-7443

ETA Call: Y

Owner: MFAS DIRECT LLC

(408) 821-2729

Contractor: DAT NGUYEN CAL VALLEY CONSTRUCTION

Cellular: (408) 449-3626

Folder Name: TRINH RESIDENCE (BEPM 100%) Subtype: Single Family

Work Proposed: New Construction

Comments:

Related Permits:

Insp Time:

1:00

Inspection time listed at the left includes 10 minutes travel time.

Next Inspections Suggested

Number of Units:

01

Time inspection completed

Code	Description	O K	P A	C N	N R	N N	R F	Code	Description	O K	P A	C N	N R	N N	R F
4 4 4	Rough Frame														
6 4 1	Rated Walls														
6 4 2	Rated Ceilings														
9 1 8	Electrical Final														
9 2 8	Plumbing Final														
9 3 8	Mechanical Final			X											
9 4 8	Building Final														
4 3 3	ROUGH DUCTS/FLUES	•													

Inspection Code: OK = Approved, PA = Partial Approval, CN = Correction Notice, NR = Not Ready, NN = Not Necessary, RF = Re-Inspection Fee Due

Remarks:

433- PREVIOUSLY OK'D ON 7/17/15 BY P. LEWIS
 MOST OF TIME SPENT SIFTING THROUGH PAPERWORK, INSPECTED F1
 ① PROVIDE INTUMESCENT CAULK AT COMBUSTIBLE PENETRATIONS AND MUD TIGHT
 TO RIGID DUCT; ② UNITS NOT FASTENED PER F1 DETAIL; ③ OUT OF TIME
 TO COMPLETE INSPECTION OF F2 - HOWEVER, COMPENSATE DOES NOT
 HAVE 1/8" PER FT SLOPE MAY NOT BE A COMPLETE INSPECTION AND 3,
 ADDITIONAL UNITS TO BE INSPECTED

You have a total of -0.25 hour(s) remaining on this project as of Wednesday, September 12 2018 10:53:56 AM.

Inspector's Signature:

Print:

DMARTIN1

Date:

09/13/18

Page: 1 of 1